

CONDUIT INSTALLATION REQUIREMENTS
PER NATIONAL GRID'S SPECIFICATIONS.
ALL ELECTRIC CONDUIT CROSSINGS SHOULD
BE INSTALLED NOT MORE THAN 48 INCHES
DEEP. GAS CONDUIT TO BE INSTALLED NOT
MORE THAN 28 INCHES DEEP.
THE CONDUIT TO BE CAPPED, STAKED,
LABELLED AND CONTAIN PULL ROPES.
THE ENDS OF THE CONDUITS SHALL
EXTEND 5 FT BEYOND THE PAVED
PORTION OF THE ROAD.
GENERAL INFORMATION:
TRENCHING BY NATIONAL GRID
20 LOTS-SECTION 4
SITE APPROX. 2300 SQ FT
APPROX. 16KW-PER DEVELOPER
SERVICE: 120/240 200 AMP

FOR NOTES AND
DETAIL DRAWINGS
SEE SHEET #2

Revision #1:
Changed fuse size
on pole #42-1 from
25 amp to 80 amp
to accommodate
entire URD.

30-167-16-00 50KVA
Ph A Mtg ERMCO mo/y 06/11

